



Reg.no. 2005/087037/23
P O Box 32422
GLENSTANTIA
0010

Phone: (012) 349 2929
Fax: (012) 349 1519
Cell: 082 892 4565/083 654 9972

Cabletronics cc
P O Box 3136
Dalview
1544

Attention: Mr Tobie du Plessis

2 August 2011

Dear Sir

COMPLIANCE: "KABELCON" PH120-140 FIRE RESISTANT CABLE

We hereby certify that Cabletronics has submitted the abovementioned cable for the evaluation of its fire resistance.

The 1 mm² single pair "Kabelcon" PH120-140 was tested for a survival period of 140 minutes as stated in section 4.1 of BS EN 50200:2006 (our reference FTC11/067a)

The cable complies with the recommendations as set out in section 8.19.2e of SANS 10139:2007.

Yours faithfully

K van Dyk
Fire Technology & Consulting Services
T/a **FIRELAB**